Clarification Log

Project Title: **2021 Manhole Rehabilitation**

Project Number: **P21168**

Date	Question	Response
11/22/2021	*Question from the Pre-Bid Meeting:* How far down in the sewer inspection camera logged in the sanitary metal pipe?	The inspection camera is lodged in a metal sanitary sewer pipe, 4-inch in diameter at a depth of 4.5’-5’.