

Clarification Log

Project Number: P21151

Project Title: Centennial Blvd Overlay (Aspen-Prescott)

Date	Question	Response
2/28/2022	What is included in bid item 210 general excavation?	General excavation includes removal the asphalt, rock, and soil from the in front of the ADA ramps where we are saw cutting and removing the pavement section. Bid item 200 (removal of curb ramp, walk, curb, and surfacing) includes removal of the existing curb ramp, sidewalk, curb and any other surfacing behind the curb. Any removal of rock or soil under the existing sidewalks or curbing is included in general excavation.
2/28/2022	How is the asphalt Alternative to bd included in the bid?	Please provide a separate unit cost per ton for non-fiber asphalt "level 2, ½ inch ACP mixture". Please see the updated bid item list and specifications.
3/2/2022	Can the city provide a specification on the fiber mixture that they want? I did not find a specification section for the fiber mixture.	See Bid Submittal, Revised 3-2-2022, page 3 (Alternative A) 00744.11 (b) Specs updated on page #13 on Special Provisions-Section B.
3/4/2022	Can you provide a unit cost for item 280 with fibers and provide an alternative without fibers. <i>The Agency will use the unit cost to make a selection.</i>	The City of Springfield will stick with the way we are currently asking for the alternate; however, we updated the bid schedule to call for a unit cost vs. total cost reduction. (<i>see Page #3 (Alternative A) of the bid submittal for revised language</i>)
3/10/2022	Section A and Section B page numbers have been updated.	3/4/2022- Bid Submittal listed Specification Changes to Section B, Page 13. The pages have been renumbered. The update to Specification 00744.11 is now on Page 14.